



Telephone/Fax No: 0824-2423169
E-mail: ceemng@kpwd.gov.in

No. PWD/MNG/JE-1/Stability Certificate/Lourdes school/2019-2020/4073-74. Dated: 29-08-2019

To.

Principal,
Lourdes Central School,
Bejai, Mangaluru - 575004.

Sir,

Sub:- Issue of Building Safety Certificate to Lourdes Central School, Bejai,
Mangaluru - Reg

Ref:- Letter No:602 :dated: 26.08.2019 of Assistant Executive Engineer, Public Works, Ports and Inland Water Transport Department Sub Division, Mangaluru

Advert to the above subject and reference, the building wherein Lourdes Central School Bafai, Mangaluru is inspected by the Assistant Executive Engineer, Public Works, Ports and Inland Water Transport Department Sub Division, Mangaluru. The foundation and superstructure of the building is found stable for functioning of educational activities for the year 2019-20 and Safety Certificate of the Building is enclosed for your information and further needful.

Yours faithfully

Rev Fr JOHNSON L SEQUEIRA
PRINCIPAL
LOURDES CENTRAL SCHOOL
Bejai, Mangalore - 575 004, Karnataka
Mobile No.: 94496 15081
Email : principal@lourdescentralschool.com
School Aff. No. 830120, School Code : 45104

Executive Engineer
Public Works, Ports and Inland Water
Transport Department Mangaluru Division, Mangaluru.



GOVERNMENT OF KARNATAKA
(Public Works, Ports and Inland Water Transport Department)

ISO 9001:2015: Certified Organisation
ISO 14001:2004: Certified Organisation
Website: <http://www.kpwd.gov.in>

Telephone/Fax No: 0824-2423169
E-mail: genmg@kpwd.gov.in


CERTIFICATE

This to Certified that the Educational Institution Building belongs to Lourdes Central School are situated at Bejai, Mangaluru to St. Francis Xavier Church Campus, Bejai, Mangaluru - 575004.

There are two buildings in the premises and a playground is stretched between these two buildings. The main building with the school office consists of Ground floor, first floor, second floor, Third floor with square shaped as the roof.


The School building is framed structure with coloums, beam and walls. There is no need of any major additional work at present. The foundation and superstructure is sound and stable and the future estimated lift may be considered as 20 years if maintained properly and periodically.

Certify that the existing School building is very well maintained and does not required any major repairs immediately. Assistant Executive Engineer has visited the School personally and found that foundation and superstructure of the building is stable and has an estimated future about 20 years, provided proper periodic maintainance is carried out.


Rev Fr JOHNSON L SEQUEIRA
PRINCIPAL

LOURDES CENTRAL SCHOOL
Bejai, Mangalore - 575004, Karnataka
Mobile No.: 94496 15081

Email : principal@lourdescentralschool.com
School Aff. No. 830120, School Code : 45104


Executive Engineer
Public Works, Ports and Inland Water
Transport Department Mangaluru Division, Mangaluru.